Annual Drinking Water Quality Report for 2001

Dillon Valley District

PWSID # 159040

Esta es informacion importante. Si no la pueden leer, necesitan que alguien se la traduzca.

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. Our water comes from Laskey Gulch and Straight Creek.

If you have any questions about this report or concerning your water utility, please contact Francis Winston at 970-513-4120 or e-mail him at fwinston@ldfr.org

We want our valued customers to be informed about their water utility. If you want to learn more, please call the above contact about the utility or any scheduled public meetings.

All public water systems are required to have a source water assessment completed by August 2003. To find out what our system has been doing, call the above contact.

Some people may be more vulnerable to contaminants in drinking water than the public in general.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and microbiological contaminants is available by calling the EPA Safe Drinking Water Hotline at 1-800-426-4791.

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- > Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- > Pesticides and herbicides that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

The table contains many terms and abbreviations that may be unfamiliar. To help you better understand these terms we've provided the following definitions:

• Action Level (AL): The concentration of a contaminant, if exceeded, triggers treatment or other requirements a water system must follow.

- High Solids (HS): High Solids, alpha was not tested.
- Maximum Contaminant Level (MCL): The "maximum allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG): The "goal" is the level of a contaminant in drinking water, below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant, below
 which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of
 disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers in water longer than 10 micrometers
- Millirems per Year (mrem/year): A measure of radiation absorbed by the body.
- Nephelometric Turbidity Unit (**NTU**): Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of five NTU is just noticeable to the average person.
- Non-Detects (**ND**) or Below Detection Level (**BDL**): Laboratory analysis indicates that the constituent is not present. ("<" Symbol for less than, the same as ND or BDL)
- Not Tested (**NT**): Not tested.
- Parts per billion (**ppb**) or Micrograms per liter (μ **g/l**): One part per billion corresponds to one minute in 2,000 years, or one penny in \$10,000,000.
- Parts per million (ppm) or Milligrams per liter (mg/l): One part per million corresponds to one minute in two years or one penny in \$10,000.
- Parts per quadrillion (**ppq**) or Picograms per liter (**pg/l**): One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000.
- Parts per trillion (**ppt**) or Nanograms per liter (**ng/l**): One part per trillion corresponds to one minute in 2,000,000 years, or one penny in \$10,000,000,000.
- PicoCuries per Liter (pCi/l): A measure of radioactivity in water.
- Treatment Technique (TT): A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
- Variances and Exemptions: State permission not to meet an MCL or a treatment technique under certain conditions.

Violations: Dillon Valley District had no violations for 2001.

Our system has a variance, exemption, or waiver for Dioxin, Glyphosate, Nitrite, Cyanide and Abestos.

Additional Information

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Some of our data, though representative, may be more than one year old.

This table shows the results of our monitoring for the period of January 1 to December 31, 2001 unless otherwise noted.

Microbiological Contaminants

Contaminant	MCL	MCLG	CCR Unit	Level Detected	Violation Yes or No	Sample Date	Likely Source of Contamination
Total Coliform Bacteria	System collects<40 samples: 1 positive monthly sample	0	Absent or Present	Absent	No	Monthly	Naturally present in the environment
Fecal coliform and E. Coli	A routine sample & a repeat sample are total coliform positive, & one is also fecal coliform or <i>E. coli positive</i>	0	Absent or Present	Absent	No		Human and animal fecal waste
Turbidity Lowest Monthly Percent of readings above the TT limits	TT	N/A	NTU	100 %			Soil runoff

Radionuclides

Contaminant	MCL	MCLG	CCR Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Beta/photon emitters	4	0	mrem/yr	0.9	No	October 10, 2001	Decay of natural and man-made deposits
Alpha emitters	15	0	pCi/l	0.0	No	October 10, 2001	Erosion of natural deposits
Combined radium	5	0	pCi/l	0.21	No	Nov. 28, 2000	Erosion of natural deposits
Uranium *Effective December 2003	30	0	μg/l	NT		NT	Erosion of natural deposits

Lead and Copper

Contaminant	MCL	MCLG	CCR Units	Level Detected/ Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Copper	1.3	1.3	ppm	0.15	No	Jan. 1, 1999 to Dec. 31, 1999	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	15	0	ppb	3.0	No	Jan. 1, 1999 to Dec. 31, 1999	Corrosion of household plumbing systems, erosion of natural deposits

Inorganic Contaminants

Contaminant	MCL	MCLG	CCR Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Antimony	6	6	ppb	BDL	No	Aug. 30, 2001	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic * Effective January 23, 2006 (Until then, the MCL is 0.05 mg/l (50 ppb) and there is no MCLG.)	10	0	ppb	BDL	No	Aug. 30, 2001	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Asbestos	7	7	MFL	NΤ	No		Decay of asbestos cement water mains; erosion of natural deposits
Barium	2	2	ppm	BDL	No	Aug. 30, 2001	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

				Level			
Contaminant	MCL	MCLG	CCR Units	Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Contaminant	iiie B	inced.	- Cinto	, runge	10307.10	2.00	Discharge from metal refineries and coal-
						Aug. 30,	burning factories; discharge from electrical,
Beryllium	4	4	ppb	BDL	No	2001	aerospace, and defense industries
							Corrosion of galvanized pipes; erosion of
						A 20	natural deposits; discharge from metal refineries; runoff from waste batteries and
Cadmium	5	5	dqq	BDL	No	Aug. 30,	paints
Cadinan	 		PPO	DDL	100	Aug. 30,	Discharge from steel and pulp mills; erosion of
Chromium	100	100	dqq	BDL	No	2001	natural deposits
							Discharge from steel/metal factories; discharge
Cyanide	200	200	ppb	NT	No		from plastic and fertilizer factories
							Erosion of natural deposits; water additive
						Aug. 30,	which promotes strong teeth; discharge from
Fluoride	4	4	ppm	1.4	No	2001	fertilizer and aluminum factories
						1 20	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills;
Mercury (inorganic)	2	2	ppb	BDL	No	Aug. 30, 2001	runoff from cropland
(Morgane)		+	PPO	BBL	110	Aug. 30,	Runoff from fertilizer use; leaching from septic
Combined Nitrate/Nitrite	10	10	ppm	BDL	No	2001	tanks, sewage; erosion of natural deposits
							Runoff from fertilizer use; leaching from septic
Nitrate (as Nitrogen)	10	10	ppm	NT	No		tanks, sewage; erosion of natural deposits
							Runoff from fertilizer use; leaching from septic
Nitrite (as Nitrogen)	1	1	ppm	NT	No	<u> </u>	tanks, sewage; erosion of natural deposits
						1 . 20	Discharge from petroleum and metal refineries;
Selenium	50	50	nnh	BDL	No	Aug. 30, 2001	erosion of natural deposits; discharge from
Selemum	30	- 30	ppb	BDL	140		Leaching from ore-processing sites; discharge
Thallium	2	0.5	ppb	BDL	No	Aug. 30, 2001	from electronics, glass, and drug factories
Linamum	·L	1 0.5	T bbo	1 000	110	1 2001	nom electromes, glass, and drug factories

• Unregulated Inorganic Contaminants

Contaminant	MCL	MCLG	CCR Units	Level Detected/ Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Nickel	N/A	N/A	Mg/l	BDL	N/A	Aug. 30, 2001	
Sodium	N/A	N/A	Mg/l	11	N/A	Aug. 30, 2001	
Sulfate	N/A	N/A	Mg/l	10	N/A	Aug. 30, 2001	

• Synthetic Organic Contaminants, including Pesticides and Herbicides

Contaminant	MCL	MCLG	CCR Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
2,4-D	70	70	ppb	BDL	No	Sept. 5, 2000	Runoff from herbicide used on row crops
2,4,5-TP (Silvex)	50	50	ppb	BDL	No	Sept. 5, 2000	Residue of banned herbicide
Acrylamide	TT	0		BDL	No	Sept. 5, 2000	Added to water during scwage/wastewater treatment
Alachlor	2	0	ppb	BDL	No	Sept. 5, 2000	Runoff from herbicide used on row crops
Atrazine	3	3	ppb_	BDL	No	Sept. 5, 2000	Runoff from herbicide used on row crops
Benzo (a) pyrene (PAH)	200	0	ppt	BDL	No	Sept. 5, 2000	Leaching from linings of water storage tanks and distribution lines
Carbofuran	40	40	ppb	BDL	No	Sept. 5, 2000	Leaching of soil furnigant used on rice and alfalfa
Chlordane	2	0	ppb	BDL	No	Sept. 5, 2000	Residue of banned termiticide
Dalapon	200	200	ppb	BDL	No	Sept. 5, 2000	Runoff from herbicide used on rights of way

Contaminant	MCL	MCLG	CCR Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Di (2-ethylhexyl) adipate	400	400	ppb	BDL	No	Sept. 5, 2000	Discharge from chemical factories
Di (2-ethylhexyl) phthalate	6	0	ppb	1	No	Sept. 5, 2000	Discharge from rubber and chemical factories
Dibromochloropropane	200_	0	ppt	BDL	No	Sept. 5, 2000	Runoff/leaching from soil furnigant used on soybeans, cotton, pineapples, and orchards
Dinoseb	7	7	ppb	BDL	No	Sept. 5, 2000	Runoff from herbicide used on soybeans and vegetables
Diquat	20	20	ppb	BDL	No_	Sept. 5, 2000	Runoff from herbicide use
Dioxin [2,3,7.8-TCDD]	30	0	Ppq	NT	No		Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall	100	100	ppb	BDL	No	Sept. 5, 2000	Runoff from herbicide use
Endrin	2	2	ppb	BDL	No	Sept. 5, 2000	Residue of banned insecticide
Epichlorohydrin	TT	0		BDL	No	Sept. 5, 2000	Discharge from industrial chemical factories; an impurity of some water treatment chemicals
Ethylene dibromide	50	0	ppt	BDL	No	Sept. 5, 2000	Discharge from petroleum refineries
Glyphosate	700	700	ppb	NT	No		Runoff from herbicide use
Heptachlor	400	0	ppt	BDL	No	Sept. 5, 2000	Residue of banned temiticide
Heptachlor epoxide	200	0	ppt	BDL	No	Sept. 5, 2000	Breakdown of heptachlor
Hexachlorobenzene	1	0	ppb	BDL	No	Sept. 5, 2000	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclo pentadiene	50	50	ppb	BDL	No	Sept. 5, 2000	Discharge from chemical factories
Lindane	200	200	ppt	BDL	No	Sept. 5, 2000	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor	40	40	ppb	BDL	No	Sept. 5, 2000	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
Oxamyl [Vydate]	200	200	ppb	BDL	No	Sept. 5, 2000	Runoff/leaching from insecticide used on apples, potatoes and tomatoes
PCBs [Polychlorinated biphenyls]	500	0	ppt	BDL	No	Sept. 5, 2000	Runoff from landfills; discharge of waste chemicals
Pentachlorophenol	1	0	ppb	BDL	No	Sept. 5, 2000	Discharge from wood preserving factories
Picloram	500	500	ppb	BDL	No	Sept. 5, 2000	Herbicide runoff
Simazine	4	4	ppb	BDL	No	Sept. 5, 2000	Herbicide runoff
Toxaphene	3_	0	ррь	BDL	No	Sept. 5, 2000	Runoff/leaching from insecticide used on cotton and cattle

• Volatile Organic Contaminants

Contaminant	MCL	MCLG	CCR Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
D	5	0	1-	BDL	No	Sept. 5, 2000	Discharge from factories; leaching from gas storage tanks and landfills
Benzene	3	0	ppb	BDL	INO	 	Storage tanks and fandrins
Bromate	10	0	ppb	BDL	No	Sept. 5, 2000	By-product of drinking water chlorination
Carbon tetrachloride	5	0	ppb	BDL	No	Sept. 5, 2000	Discharge from chemical plants and other industrial activities
Chloramines	MRDL = 4	MRDLG = 4	ppm	BDL	No	Sept. 5, 2000	Water additive used to control microbes
Chlorine	MRDL = 4	MRDLG = 4	ppm	BDI	No	Sept. 5, 2000	Water additive used to control microbes

	1		CCR	Level Detected	Violation	Sample	
Contaminant	MCL	MCLG	Units	/Range	Yes or No	Date	Likely Source of Contamination
				DDI	Nia	Sept. 5,	De mus duat of deintring unitar chlorination
Chlorite	l MRDL	0.8 MRDLG	ppm	BDL	No	2000 Sept. 5,	By-product of drinking water chlorination
Chloride dioxide	= 800	= 800	ppb	BDL	No	2000	Water additive used to control microbes
Chioride dioxide			PP			Sept. 5,	Discharge from chemical and agricultural
Chlorobenzene	100	100	ppb	BDL	No	2000	chemical factories
						Sept. 5,	
o-Dichlorobenzene	600	600	ppb	BDL	No	2000	Discharge from industrial chemical factories
p-Dichlorobenzene	75	75	ppb	BDL	No	Sept. 5, 2000	Discharge from industrial chemical factories
p-Dicinorobenzene	13	13	ppo	DDL	140	Sept. 5,	Discharge from inclusional element factories
1,2-Dichloroethane	5	0	ppb	BDL	No	2000	Discharge from industrial chemical factories
						Sept. 5,	
1,1-Dichloroethylene	7	7	ppb	BDL	No	2000	Discharge from industrial chemical factories
		7.0	1 ,	201		Sept.5,	
cis-1,2-Dichloroethylene	70	70	ppb	BDL	No	2000 Sept. 5	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene	100	100	ppb	BDL	No	Sept. 5, 2000	Discharge from industrial chemical factories
trans-1,2-Diemoroeutyrene	100	100	PPO	BDE	1,0	Sept. 5,	Discharge from pharmaceutical and chemical
Dichloromethane	5	0	ppb	BDL	No	2000	factories
						Sept. 5,	
1,2-Dichloropropane	5	0	ppb	BDL	No	2000	Discharge from industrial chemical factories
D.1. 11	700	700		DDI	No	Sept. 5, 2000	Discharge from petroleum refineries
Ethylbenzene	700	700	ppb	BDL	No	Sept. 5,	Discharge from petroleum remerles
Haloacetic Acids (HAA)	60	N/A	ppb	BDL	No	2000	By-product of drinking water disinfection
			1			Sept. 5,	Discharge from rubber and plastic factories;
Styrene	100	100	ppb	BDL	No	2000	leaching from landfills
	_		,	557		Sept. 5,	
Tetrachloroethylene	5	0	ppb	BDL	No	2000 Sept. 5,	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene	70	70	ppb	BDL	No	2000	Discharge from textile-finishing factories
1,2,4-1116111010061126116	1		ppu_	1 555	, , , , ,	Sept. 5,	Discharge from metal degreasing sites and
1,1,1-Trichloroethane	200	200	ppb	BDL	No	2000	other factories
						Sept. 5,	
1,1,2-Trichloroethane	5	3	ppb	BDL	No	2000	Discharge from industrial chemical factories
Trichloroethylene	5	0	ppb	BDL	No	Sept. 5, 2000	Discharge from metal degreasing sites and other factories
TTHM	 	+	l bbo	BDL	INO	Sept. 5,	outer factories
[Total trihalomethanes]	100	0	ppb	BDL	No	2000	By-product of drinking water chlorination
						Sept. 5,	
Toluene	1	11	ppm	BDL	No	2000	Discharge from petroleum factories
A77 1 CO 1 1 1 1				DDI	N-	Sept. 5,	Leaching from PVC piping; discharge from
Vinyl Chloride	2	0	ppb	BDL	No	2000 Sept. 5,	chemical factories Discharge from petroleum factories; discharge
Xylenes	10	10	ppm	BDL	No	Sept. 5,	from chemical factories
Unregulated Org	<u> </u>						
- On egulated Org	anic Coll			Level			
			CCR	Detected/	Violation	Sample	
Contaminant	MCL	MCLG	Units	Range	Yes or No	Date	Likely Source of Contamination

N/A

N/A

N/A

Please contact us if you have any questions or concerns.

Chloroform

Bromodichloromethane

ppb

ppb

N/A

N/A

2.5

0.7

N/A

N/A

N/A